



CERTIFICATE OF APPROVAL

No CF 5423

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

FRELAN HARDWARE LTD

Unit 10 Mitcham Industrial Estate, Streatham Road,
Mitcham, Surrey, CR4 2AP
Tel: 0208 6481500

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Frelan Mortice Locks, Tubular
Deadbolts and Tubular Latches

TECHNICAL SCHEDULE

TS23 The Contribution of
Locks and Latches to The
Performance of Fire Resisting
Doorsets

TS31 The Contribution of
Emergency Exit Devices to the
Fire Resistance of Door
Assemblies

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued:
Revised:
Valid to:

18th January 2017
21st September 2020
11th March 2023





CERTIFICATE No CF 5423

FRELAN HARDWARE LTD

Frelan Mortice Locks, Tubular Deadbolts and Tubular Latches

1. The locks and latches covered by this certificate are all steel cased. This approval relates to locks and latches as follows:

Reference	Description
JL-DS60	DIN Standard Sashlock 60mm Backset
JL-DD60	DIN Standard Deadlock 60mm Backset
JL-DB60	DIN Standard Bathroom Lock 60mm Backset
JL-DL60	DIN Standard Latch 60mm Backset
JL-DN60	DIN Nightlatch 60mm Backset
JL-DE60	DIN Escape Lock 60mm Backset
JL-HDT63	Tubular Latch 63 mm case
JL-HDT76	Tubular Latch 76 mm case
JL-HDT102	Tubular Latch 102 mm case
JL-HDB63	Tubular Deadbolt 63 mm case
JL-HDB76	Tubular Deadbolt 76 mm case
JL-HDB102	Tubular Deadbolt 102 mm case

2. This certification is provided to the client for its own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. This approval relates to the use of the above locks/latches in contributing to the fire resistance performance of timber based doorsets, as defined in BS EN 1634-1 or BS 476: Part 22: 1987.
4. This approval relates to their use with the following door assemblies:-

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 60 minutes (Code ITT).

5. The locks are approved on the basis of:
- i) Initial type testing to EN 1634-1 and EN 12209
 - ii) An appraisal against TS23 and TS31
 - iii) Certification of quality management system.
 - iv) Inspection and surveillance of factory production control
 - v) On-going audit testing in accordance with TS23 and TS31 requirements



CERTIFICATE No CF 5423

FRELAN HARDWARE LTD

Frelan Mortice Locks, Tubular Deadbolts and Tubular Latches

6. The mortice locks and/or latches should only be used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) with similar size locks and strikeplates. The critical aspects of the doorset construction are considered to be the material of the door frame, the leaf to frame clearance gaps and the lipping material. Attention should be paid to these details and these should not be amended from that previously fire tested. The following minimum specification will be followed:

Timber-based assemblies:

- i) Door frame density - 450 kg/m³ (30 minutes), 640 kg/m³ (60 minutes)
 - ii) Door leaves shall have a minimum thickness of 44 mm for 30 minute applications and 54 mm for 60 minute applications.
 - iii) Lipping density - 640 kg/m³.
7. When fitted to insulated timber or mineral composite door assemblies, The required protection will be as follows:
- i) The required protection for 30 minute ITT applications will be 1 mm thick Interdens mono ammonium phosphate or graphite-based intumescent sheet material around the lock case and behind the forend and strike plate.
 - ii) The required protection for 60 minute ITT applications will be 2 mm thick Interdens mono ammonium phosphate or graphite-based intumescent sheet material around the lock case and behind the forend and strike plate. Additionally the perimeter intumescent within the frame/door edge shall by-pass the strike plate or forend by a minimum of 7.5 mm wide on each side (with the exception of the latchbolt lead where present).

Note: Failure to install the protection will invalidate this certificate

8. The mortice locks and/or latches and their associated strikeplates and keeps may only be fitted in the manner described in this certificate and subject to any limitations on the inclusion of locks/latches specified for the door leaf. This approval is applicable only to the specified locks used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and when using appropriate intumescent protection.
9. Lock assemblies not incorporating a latching mechanism shall only be fitted to proven unlatched door assemblies.



CERTIFICATE No CF 5423

FRELAN HARDWARE LTD

Frelan Mortice Locks, Tubular Deadbolts and Tubular Latches

10. The mortice locks and/or latches should only be used with doorsets which have been previously shown to be capable of providing the required fire resistance performance when tested in accordance with EN 1634-1 or BS 476: Part 22: 1987 in the proposed configuration i.e. single-leaf or double-leaf.
11. The DIN standard mortice lock/latch range with a 60mm Backset should not be fitted higher than 1100 mm from the spindle to the finished floor level of the surrounding floors. The tubular latches and deadbolts should not be fitted higher than 1200 mm from the spindle to the finished floor level of the surrounding floors.
12. The Din Standard mortice locks may incorporate Euro profile cylinders as follows:
 - i) Single cylinder
 - ii) Double cylinder
 - iii) Cylinder and thumbturn
 - iv) Brass or steel cylinders for ITT30 and 60 doorsets

Note: The hole in the door face shall follow the shape of the cylinders and be as tight as possible; furthermore the single cylinders door preparation will penetrate through only half the thickness of the door leaf)

13. Recessing for locks shall result in a tight fit, allowing for any intumescent protection where required. Mortices for the latchbolt and deadbolt behind the strikeplate shall be as small as possible.
14. The lock keeps/strikeplates shall **not** incorporate plastic back-boxes. The strikeplates may be provided with or without the latchbolt lead.
15. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.



CERTIFICATE No CF 5423

FRELAN HARDWARE LTD

Frelan Mortice Locks, Tubular Deadbolts and Tubular Latches

16. The following table shows the acceptable doorset types and fire resistance periods:

Class	Approved Door Type				
	IMM	MM	ITT	ITM	ITC
FD20	x	x	✓	x	x
FD30	x	x	✓	x	x
FD60	x	x	✓	x	x
FD90	x	x	x	x	x
FD120	x	x	x	x	x
FD240	x	x	x	x	x
E 20	x	x	✓	x	x
EI 20	x	x	✓	x	x
E 30	x	x	✓	x	x
EI 30	x	x	✓	x	x
E 60	x	x	✓	x	x
EI 60	x	x	✓	x	x
E 90	x	x	x	x	x
EI 90	x	x	x	x	x
E 120	x	x	x	x	x
EI 120	x	x	x	x	x
E 240	x	x	x	x	x
EI 240	x	x	x	x	x

Key:



- approved



- Not approved



CERTIFICATE No CF 5423

FRELAN HARDWARE LTD

Frelan Mortice Locks, Tubular Deadbolts and Tubular Latches

17. Doors are classified as the following types:

Type MM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

Type IMM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

Type ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

Type ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

Type ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

18. Approved lock/latch models and classifications.

Reference	Description	Classification to EN 12209: 2003											
JL-DS60	Din Standard Sashlock	3	X	8	1	0	G	2	B	C	2	0	
JL-DD60	Din Standard Deadlock	3	X	8	1	0	G	2	B	C	0	0	
JL-DB60	Din Standard Bathroom Lock	3	X	8	1	0	G	-	B	G	2	0	
JL-DL60	Din Standard Latch	3	X	8	1	0	G	-	B	0	2	0	
JL-HDT64	Tubular Latch 64 mm case	1	C	7	1	0	F	-	B	0	N	0	
JL-HDT76	Tubular Latch 76 mm case	1	C	7	1	0	F	-	B	0	P	0	
JL-HDT102	Tubular Latch 102 mm case	1	C	7	1	0	F	-	B	0	D	0	
JL-HDB64	Tubular Deadbolt 64 mm case	3	X	8	1	0	G	-	B	G	0	0	
JL-HDB76	Tubular Deadbolt 76 mm case	3	X	8	1	0	G	-	B	G	0	0	
JL-HDB102	Tubular Deadbolt 102 mm case	3	X	8	1	0	G	-	B	G	0	0	

Reference	Description	Classification to EN 179: 2008									
JL-DN60	DIN Nightlatch 60mm Backset	3	7	6	B	1	3	4	2	A	B/D
JL-DE60	DIN Escape Lock 60mm Backset	3	7	6	B	1	3	4	2	A	B/D

Page 6 of 7 Signed
J/062

Issued: 18th January 2017
Revised: 21st September 2020
Valid to: 11th March 2023



CERTIFICATE No CF 5423

FRELAN HARDWARE LTD

Frelan Mortice Locks, Tubular Deadbolts and Tubular Latches

Scope of approval

- Strikeplates/keeps
 - The DIN Standard range of locks/latches is approved with a range of strikeplates/keeps. All of which are steel and the a maximum size permitted for use on all doorsets is as follows:

width	25 mm (exc. Lip)
height	180 mm
thickness	1.5 mm
Latchbolt- lip height	148 mm

- The Tubular range of locks/latches is approved with a range of strikeplates/keeps. All of which are steel and the a maximum size permitted for use on all doorsets is as follows:

width	25 mm (exc. Lip)
height	65 mm
thickness	1.2 mm
Latchbolt- lip height	40 mm

- The lock keeps/strikeplates shall not incorporate plastic back-boxes
- Escape function locks
 - The locks referenced JL-DN60 and JL-DE60 when fitted to comply with the requirements for their escape function in accordance with EN 179: 2008, are only approved when fitted in conjunction with the following approved lever handle set:

JSS01	Satin Stainless Steel	RTD Lever c/w 5mm push on rose – 19mm dia
JSS13	Satin Stainless Steel	RTD Lever c/w 8mm push on rose – 19mm dia
JSS213	Satin Stainless Steel	RTD Lever c/w 8mm push on rose – 22mm dia

Further Information

Further information regarding the details contained in this certificate may be obtained from Frelan Hardware Ltd (Tel: 0208 6481500).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 7 of 7 Signed
J/062

Issued: 18th January 2017
Revised: 21st September 2020
Valid to: 11th March 2023